



**SECTION
NO SCALE**

1. 3250 PSI MIN. GRAY CONCRETE - WITH MEDIUM BROOM FINISH.
2. 1/2-INCH MIN. RADIUS TYP.
3. FINISH GRADE / 2 INCHES BELOW CONCRETE FOR PLANTER AND 1-INCH BELOW FOR TURF
4. 90% COMPACTED SUBGRADE
5. WEAKENED PLANE JOINT (2-INCH DEPTH)

NOTES:

- A. CONCRETE CROSS SLOPE SHALL BE 2 % MAX. / 1% MIN.
- B. CONCRETE LONGITUDINAL SLOPE SHALL NOT BE GREATER THAN 5% WITHOUT HANDRAILS.
- C. CONCRETE SHALL BE NATURAL GRAY COLOR.
- D. PROVIDE 3/8-INCH FELT EXPANSION JOINTS WHERE CONCRETE JOINS WITH BLOCK WALL OR OTHER STRUCTURES.
- E. ALL CONCRETE SHALL COMPLY WITH ADA REGULATIONS.
- F. ALL CONCRETE FORMS SHALL BE INSPECTED PRIOR TO POURING.
- G. ALL CONCRETE AND SUBGRADES SHALL COMPLY WITH GEOTECHNICAL REPORT.

APPROVED BY:

Jonathan George Smith

4/24/15

DIRECTOR OF PUBLIC WORKS
JONATHAN GEORGE SMITH

DATE



CITY OF MENIFEE

**CONCRETE
FLATWORK**

REVISION	BY:	APPROVED	DATE

STANDARD PLAN NO. 1301.01 SHEET 1 OF 1