



1. METAL ROOF: CORRUGATED STEEL - BERRIDGE LEAD-COPE STRAIGHT S-DECK / INSTALL PER MANUFACTURER'S SPECIFICATIONS
2. METAL TRELLIS POWDER COATED (OR (2) COATS ZINC AND PRIMER & (2) COATS SATIN FINISH PAINT); COLOR TO BE SELECTED / REFER TO MANUFACTURER'S DETAILS AND SPECIFICATIONS FOR ROOF FRAMING
3. 4-INCH X 6-INCH METAL BEAM POWDER COATED - COLOR TO BE SELECTED
4. 4-INCH X 4-INCH TUBULAR STEEL POST. SET POST FLUSH TO WALL. GROUT FILL POST SOLID. PAINT WITH (2) COATS ZINC PRIMER & (2) COATS SATIN FINISH PAINT - COLOR TO BE SELECTED
5. 6-INCH P.C.C. PAVING IN FRONT OF ENCLOSURE / 6-FOOT MIN. WIDTH
6. CONCRETE FOOTING / REFER TO STRUCTURAL ENGINEER'S SPECIFICATIONS FOR FOOTING AND REINFORCEMENTS
7. COMPACTED SUBGRADE PER GEOTECHNICAL REPORT
8. 8-INCH X 2-INCH X 16 INCHES WALL (CMU) CAP TO MATCH WALL COLOR
9. WALL - SEE NOTE A

**ELEVATION
NO SCALE**

NOTES:

- A. 8-INCH X 8-INCH X 16-INCH CMU / REFER TO STRUCTURAL ENGINEER'S SPECIFICATIONS FOR REINFORCEMENT.
- B. CONCRETE FOOTING TO ACHIEVE 4300 PSI @ 28 DAYS.

APPROVED BY:

Jonathan G. Smith

4/24/15

DIRECTOR OF PUBLIC WORKS
JONATHAN GEORGE SMITH

DATE



CITY OF MENIFEE

**TRASH ENCLOSURE
SIDE ELEVATION**

REVISION	BY:	APPROVED	DATE