



NOTE:
SEE PLAN NO. 1301.13 / SHEET 2 FOR KEYNOTES.

ELEVATION
NO SCALE

APPROVED BY:

Jonathan G. Smith

4/24/15

DIRECTOR OF PUBLIC WORKS
 JONATHAN GEORGE SMITH

DATE



CITY OF MENIFEE

TRASH ENCLOSURE
FRONT ELEVATION

REVISION	BY:	APPROVED	DATE

KEY NOTES:

1. 4-INCH X 6-INCH METAL BEAM POWDER COATED - COLOR TO BE SELECTED
2. 4-INCH X 4-INCH TUBULAR STEEL POST. SET POST FLUSH TO WALL. GROUT FILL POST SOLID. PAINT WITH (2) COATS ZINC PRIMER & (2) COATS SATIN FINISH PAINT - COLOR TO BE SELECTED
3. GATE FRAME CONTINUOUS, ATTACH GATE FRAME TO STEEL POST WITH 3 HEAVY DUTY HINGES. CONTRACTOR SHALL SUPPLY SHOP DRAWINGS FOR APPROVAL PRIOR TO CONSTRUCTION
4. CMU WALL / REFER TO STRUCTURAL ENGINEER'S SPECIFICATIONS FOR REINFORCEMENT
5. CONCRETE FOOTING / REFER TO STRUCTURAL ENGINEER'S SPECIFICATIONS FOR REINFORCEMENT
6. HEAVY DUTY HINGES
7. METAL TRELLIS POWDER COATED (OR (2) COATS ZINC AND PRIMER & (2) COATS SATIN FINISH PAINT); COLOR TO BE SELECTED / REFER TO SHOP DRAWINGS FOR ROOF FRAMING
8. 3-INCH X 8-INCH X 1/4-INCH THICK GALVANIZED STEEL STOP PLATE AND LOCKABLE KEEPER. WELD TO GATE FRAME - AS SHOWN / CONTRACTOR SHALL SUBMIT SHOP DRAWINGS FOR APPROVAL
9. MINI-V-BEAM 26 GAUGE WITH ENDURA CLAD FINISH AS MANUFACTURED BY ASC PACIFIC INC. OR APPROVED EQUAL. SPOT WELD TO ANGLE FRAME (CONTRACTOR TO SUBMIT SHOP DRAWINGS)
10. 9-INCH X 1/2-INCH GALVANIZED STEEL DIAGONAL CROSS BRACE / FILLET WELD TO FRAME AND SPOT WELD TO MINI-V-BEAM (AT BACK OF GATE)
11. HEAVY DUTY DROP CANE BOLT. ATTACH TO GATE FRAME. SET 1 - 6 INCHES LONG X 1-INCH O.D. GALVANIZED PIPE SLEEVE TO ACCEPT BOLT. 'STANLY' CD 10009-18 INCHES OR APPROVED EQUAL
12. COMPACTED SUBGRADE PER GEOTECHNICAL REPORT
13. 6-INCH THICK P.C.C. CONCRETE PAD WITH 6 X 6 X 10 WWM
14. METAL ROOF: CORRUGATED STEEL - BERRIDGE LEAD-COPE STRAIGHT S-DECK /INSTALL PER MANUFACTURER'S SPECIFICATIONS
15. 8-INCH X 2-INCH X 16-INCH CMU CAP TO MATCH WALL COLOR
16. DISABLED ACCESSIBLE RAMP & HANDRAIL IF REQUIRED - REFER TO STANDARD PLAN NO. 1301.11
17. CONCRETE CURB

NOTES:

- A. CONCRETE FOOTING TO ACHIEVE 4300 PSI @ 28 DAYS.
- B. TRASH BINS - SIZE AND NUMBER AS REQUIRED BY CITY. (SINGLE BIN SHOWN)

APPROVED BY:

Jonathan G. Smith

4/24/15

DIRECTOR OF PUBLIC WORKS
JONATHAN GEORGE SMITH

DATE



CITY OF MENIFEE

**TRASH ENCLOSURE
FRONT ELEVATION
(KEY NOTES)**

REVISION	BY:	APPROVED	DATE

STANDARD PLAN NO. 1301.13 SHEET 2 OF 2