



**SECTION
NO SCALE**

1. ARTIFICIAL GRASS FIBER (100% POLYETHYLENE MONOFILAMENT) WITH SECONDARY THATCH FIBER AND BACKING (SEE NOTE F)
2. PERMEABLE GEOTEXTILE WEED BARRIER
3. CRUSHED AGGREGATE BASE, CLASS II (COMPACT 90 %) / 3/4-INCH MINUS WITH FINES
4. 2 X 4 NAILER BOARD / RECYCLED COMPOSITE OR TREATED LUMBER
5. NATIVE SUBGRADE - LEVEL (COMPACT 90 %)
6. SCREWS TO ATTACH TURF TO NAILER (1-IN LENGTH MIN.)
7. CONCRETE CURB OR HARDSCAPE EDGE - TYP.
8. SPIKES AT 3 FEET O.C. TRIANGULAR SPACING
9. DOWEL NAILER BOARD TO CONCRETE (OR OTHER APPROVED CONNECTION)
10. INFILL (SEE NOTE C)

NOTES:

- A. TURF SHALL BE INSTALLED AND SEAMED WITH ADJACENT PIECES RUNNING IN THE SAME DIRECTION. ALL SEAMS SHALL HAVE SEAMING GLUE & 6-INCH WIDE SEAMING TAPE.
- B. SECURE TURF ON BASE W 6-INCH 60D FLAT HEAD GALV. NAILS 3 FEET ON INT. FIELD. USE 1-INCH TARPON SCREWS @ 12 INCHES O.C. ALONG PERIMETER NAILER.
- C. INFILL SHALL BE IN ACCORDANCE W/MANUFACTURER'S SPECIFICATIONS - WASHED SILICA SAND & CRYOGENIC RUBBER.
- D. POWER BROOMING IS THE LAST STAGE OF TURF INSTALLATION.
- E. MINIMUM PRODUCT WARRANTY SHALL BE 8 YEARS, WITH MIN. 15 YEAR LIFE EXPECTANCY.
- F. TURF BACKING SHALL BE 100 % PERMEABLE (NON-ABSORBENT).
- G. TURF SHALL BE FIRE RETARDANT, AND 100 % RECYCLABLE.
- H. INSTALLATION SHALL BE COMPLETED IN ACCORDANCE WITH THE MANUFACTURER'S SPECIFICATIONS AND CITY DEVELOPMENT CODE REQUIREMENTS.

APPROVED BY:

Jonathan G. Smith

4/24/15

DIRECTOR OF PUBLIC WORKS
JONATHAN GEORGE SMITH

DATE



CITY OF MENIFEE

**ARTIFICIAL TURF
(PARKWAY AREA ONLY)**

REVISION	BY:	APPROVED	DATE