



1. FINISH GRADE
2. CLEAN BACKFILL (REFER TO SPECIFICATIONS FOR MATERIALS AND COMPACTION)
3. NON-PRESSURE LATERAL LINE PER LEGEND
4. PRESSURE SUPPLY LINE PER LEGEND
5. CONTROL WIRES - INSTALL ADJACENT TO PRESSURE SUPPLY LINE
6. PROVIDE 3 INCHES OF CLEAN SAND BELOW PRESSURE MAINLINE
7. REFER TO SPECIFICATIONS FOR PIPE DEPTH AND CLEARANCE
8. DETECTABLE MARKING TAPE ABOVE PRESSURE SUPPLY LINE

SECTION
NO SCALE

NOTES:

A. WIRE SHALL BE PLACED ON SAME SIDE OF PRESSURE SUPPLY LINE FOR ENTIRE LENGTH OF WIRE RUN.

APPROVED BY:

Jonathan George Smith

4/24/15

DIRECTOR OF PUBLIC WORKS
JONATHAN GEORGE SMITH

DATE



CITY OF MENIFEE

**TRENCHING AND
PIPE INSTALLATION**

REVISION	BY:	APPROVED	DATE

STANDARD PLAN NO. 1302.13 SHEET 1 OF 1