



- 1. TRACT BLOCK WALL (TYP.)
- 2. STREET SIDEWALK (TYP.)
- 3. STREET CURB (TYP.)
- 4. IRRIGATION SLEEVES AS REQ'D / EXTEND 24 INCHES BEYOND EDGE OF CURB RADIUS AND 7 FT.- 6 IN. FROM THE STREET CURB TYP.
- 5. BLOCK PILASTER TYP.
- 6. PROVIDE SEPARATE SLEEVE FOR WIRING PER SPECS. (4-INCH MIN.)
- 7. TYPICAL PLANTER/MONUMENT ENTRANCE
- 8. 24 INCHES BEYOND B.C.R. (BEGIN CURB RADIUS) TYP.
- 9. 18 INCHES FROM BACK OF SIDEWALK TYP. (7 FT.- 6 IN. FROM CURB FACE)
- 10. ISOLATION VALVE PRIOR TO STREET CROSSING PER DETAILS
- 11. MAINLINE PER PLAN, SPECS AND DETAILS. INSTALL 18 INCHES FROM BACK OF SIDEWALK

NOTES:

- A. PIPING SHALL BE 4 INCHES MIN. FROM EACH OTHER AND 24 INCHES FROM OTHER UTILITY LINES.
- B. SLEEVES SHALL BE SCH. 40 2X THE SIZE OF THE LINE SIZE.
- C. SLEEVES SHALL HAVE A MIN. COVER OF 24 INCHES AND NO DEEPER THAN 36 INCHES.

PLAN
NO SCALE

APPROVED BY:

Jonathan George Smith

4/24/15

DIRECTOR OF PUBLIC WORKS
JONATHAN GEORGE SMITH

DATE



CITY OF MENIFEE

**PRESSURE
MAINLINE STREET
CROSSING (TYP.)**

REVISION	BY:	APPROVED	DATE
1	G.H.	J.S.	1/15/16