



1. REMOTE CONTROL VALVE AT TOP OF SLOPE (ONLY WHEN NECESSARY)
2. SCHEDULE 40 UVR PVC PER SPECS. - SIZE PER PLAN
3. SENNINGER INLINE PRESSURE REGULATOR
4. SCHEDULE 40 UVR PVC FROM VALVE - SIZE PER PLAN
5. PVC SWING CHECK VALVE
6. SCHEDULE 40 UVR PVC FROM VALVE WHEN INSTALLED AT TOP OF SLOPE
7. 3/4-INCH X 6-INCH SCHEDULE 80 NIPPLE USE CUT NIPPLE FOR TOP OF LINE WHERE TEE IS SLIP X SLIP
8. SCHEDULE 40 UVR PVC TEE - LINE SIZE BY 3/4-INCH S X S X T
9. EPOXY COATED REBAR J-HOOK @ 8' SPACING
10. UVR PVC LATERAL TO FILTER AND VALVE
11. BASKET FILTER
12. REMOTE CONTROL VALVE AT TOE OF SLOPE (TYPICAL CONFIGURATION)

NOTES:  
 A. FLUSH LATERAL LINES COMPLETELY BEFORE INSTALLATION OF PRESSURE REGULATORS.  
 B. ALL PIPING SHALL BE PRIMED PRIOR TO GLUE APPLICATION PER SPECS.  
 C. ALL PIPING SHALL BE BURIED 4 INCHES MIN.

**PLAN**  
**NO SCALE**

APPROVED BY:

*Jonathan George Smith*

4/24/15

DIRECTOR OF PUBLIC WORKS  
 JONATHAN GEORGE SMITH

DATE



CITY OF MENIFEE

**CHECK VALVE &  
 PRESSURE REG.**

REVISION	BY:	APPROVED	DATE