



1. FINISH GRADE
2. 6-INCH ROUND VALVE BOX - SEE NOTE A
3. AIR/ VACUUM RELIEF VALVE - REFER TO LEGEND
4. 1/2-INCH PVC COUPLING (T x T) / SCH 40
5. 1/2-INCH SCH 80 PVC RISER (LENGTH AS REQUIRED)
6. BRICK SUPPORTS (THREE)
7. 3/4-INCH CRUSHED ROCK SUMP (ONE CU.FT. MIN.)
8. PVC PIPE AND FITTINGS - REFER TO SPECIFICATIONS FOR DEPTH
9. 1-INCH IN LAWN, 3 INCHES IN SHRUB AREAS
10. 2 INCHES
11. SEE SPECIFICATIONS FOR DEPTH

NOTE:

A. HEAT BRAND "AR" ON VALVE BOX LID.

SECTION
NO SCALE

APPROVED BY:

Jonathan George Smith

4/24/15

DIRECTOR OF PUBLIC WORKS
JONATHAN GEORGE SMITH

DATE



CITY OF MENIFEE

**AIR VACUUM
RELIEF VALVE
ON PVC**

REVISION	BY:	APPROVED	DATE

STANDARD PLAN NO. 1302.36 SHEET 1 OF 1