



**SECTION
NO SCALE**

1. CONCRETE BAND (IF SPECIFIED) WITH A SCORE JOINT EVERY 10 FEET OR MATCH WITH CURB AND GUTTER
2. (2) #3 REBAR (HORIZ.) CONT. WITH 12" OVERLAP
3. COLD-JOINT
4. 6-TO 12-INCH RANDOM COBBLE PAVING WITH 1/4-TO 1/2-INCH JOINTS. COBBLE SHALL BE SET IN CONCRETE (3250 PSI) MORTAR MIX
5. CONCRETE BASE (3250 PSI)
6. COMPACTED SUBGRADE PER STRUCTURAL SOILS REPORT (90% MINIMUM)

NOTES:

- A. SPACE BETWEEN ROCK SHALL NOT EXCEED 1-INCH. EXPOSED COBBLE HEIGHT SHALL NOT EXCEED 1.5-INCHES.
- B. GENERAL APPEARANCE SHALL BE UNIFORM CROWNED PLANE WITHOUT PEAKS AND VALLEYS.

PERCENTAGE OF COBBLE ROCK TO BE INSTALLED:

40%	12"
30%	10"
20%	8"
10%	6"

NO IRON IS ALLOWED IN COBBLE ROCK

APPROVED BY:

Jonathan G. Smith

1/15/16

DIRECTOR OF PUBLIC WORKS
JONATHAN GEORGE SMITH

DATE



CITY OF MENIFEE

**COBBLE PAVING W/
CONCRETE BAND**

REVISION	BY:	APPROVED	DATE

STANDARD PLAN NO. 1301.16 SHEET 1 OF 1