



1. FINISH GRADE
2. 6-INCH ROUND VALVE BOX
3. AIR/ VACUUM RELIEF VALVE - REFER TO LEGEND
4. PVC SCHEDULE 40 COMP X FIPT X COMP TEE
5. BRICK SUPPORTS (THREE)
6. 3/4-INCH CRUSHED ROCK SUMP (1 CU. FT. MIN.)
7. SUBSURFACE TUBING - SEE SPECIFICATIONS
8. 1-INCH IN LAWN, 2 INCHES IN SHRUB AREAS
9. 2 INCHES
10. SEE SPECIFICATIONS FOR DEPTH

**SECTION  
NO SCALE**

APPROVED BY:

*Jonathan George Smith*

4/24/15

DIRECTOR OF PUBLIC WORKS  
JONATHAN GEORGE SMITH

DATE



**CITY OF MENIFEE**

**AIR VACUUM  
RELIEF VALVE ON  
DRIP TUBING**

REVISION	BY:	APPROVED	DATE

STANDARD PLAN NO. 1302.37 SHEET 1 OF 1