



1. 10-INCH ROUND VALVE BOX W/ LOCKING SS BOLT (SEE SPECIFICATIONS) - DO NOT CUT ADDITIONAL HOLES INTO BOX
2. FINISH GRADE
3. 8-INCH PVC CLASS 160 SLEEVE - TO REST ON TOP OF EDGE OF VALVE ASSEMBLY
4. ISOLATION GATE VALVE WITH 2-INCH SQUARE OPERATING NUT - SEE SPECIFICATIONS
5. 3/4-INCH CRUSHED ROCK UNDER VALVE BOX - FILL TO TOP OF VALVE BOX HOLES
6. INSTALL FILTER FABRIC AROUND GRAVEL SUMP AND VALVE BOX
7. FLG X SLP SCH. 80 PVC FLANGE (2 REQUIRED)
8. PRESSURE SUPPLY LINE - REFER TO PLAN FOR SIZE
9. CONCRETE BRICK SUPPORTS - 3 EACH
10. 1/2-INCH GALV. WIRE MESH BELOW BOX

SECTION
NO SCALE

APPROVED BY:

Jonathan George Smith

1/15/16

DIRECTOR OF PUBLIC WORKS
JONATHAN GEORGE SMITH

DATE



CITY OF MENIFEE

**ISOLATION
GATE VALVE**

REVISION	BY:	APPROVED	DATE

STANDARD PLAN NO. 1302.41 SHEET 1 OF 1